

PORTABLE APPLIANCE TEST CERTIFICATE

GRAHAM WEBB ELECTRONICS Tel: 01525 375755

Customer Creative Sound services				
Site Address				
H/O Address 43 Pendlebury Bracknell Berks RG12 7RB				
Contact Barry Gooden 07970 867524				
Manufacturer	Kewtech	Model	KT71	Serial 7000565
		Date Calibrated	28/8/2009	

DATE OF TEST	26/06/2010
NEXT TEST DATE	25/06/2011
ENGINEER	GW
AUTHORISATION No.	ZMN 251-1

ID No.	Label No.	Description	Location	Manufacturer	Serial No	Class 1-1 2-2 3-IT	Visual Pass /Fail	Fuse (Amps)	Earth 20A / 200ma	Bond	Insulation	Leak age	Comments	PASS	FAIL
0001	11769	lead				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0002	11730	Amplifier		Rauch		3	Pass		200ma	pass	N/A	P/F Pass		Pass	
0003	11731	Amp/graphic		europower		3	Pass	13	200ma	pass	N/A	P/F Pass		Pass	
0004	11732	Amp/graphic		tamp/mxr		3	Pass	13	200ma	pass	N/A	P/F Pass		Pass	
0005	11733	Amplifier		caudio		3	Pass	13	200ma	pass	N/A	P/F Pass		Pass	
0006	11734	Amp/co		caudio		3	Pass		200ma	pass	N/A	P/F Pass		Pass	
0007	11735	lead				1	Pass	10	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0008	11736	mixer		soundcraft		3	Pass		200ma	pass	N/A	P/F Pass		Pass	
0009	11737	2 x graphic				3	Pass		200ma	pass	N/A	P/F Pass		Pass	
0010	11738	cd playr		philips		2	Pass		N/A		P/F Pass	N/A		Pass	
0011	11739	univerb		lexicon		2	Pass		N/A		P/F Pass	N/A	built in ext lead	Pass	
0012	11740	light		dts		1	Pass		20A	pass	P/F Pass	N/A		Pass	
0013	11741	light		dts		1	Pass		20A	pass	P/F Pass	N/A		Pass	
0014	11742	light		dts		1	Pass		20A	pass	P/F Pass	N/A		Pass	
0015	11743	light		dts		1	Pass		20A	pass	P/F Pass	N/A		Pass	
0016	11744	light				1	Pass		20A	pass	P/F Pass	N/A		Pass	
0017	11745	light				1	Pass		20A	pass	P/F Pass	N/A		Pass	
0018	11746	light				1	Pass		20A	pass	P/F Pass	N/A		Pass	
0019	11747	light				1	Pass		20A	pass	P/F Pass	N/A		Pass	
0020	11748	10 way lead				1	Pass		20A	pass	P/F Pass	N/A	polarity ok	Pass	
0021	11749	lead				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0022	11750	lead				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0023	11751	4 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0024	11752	6 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0025	11753	4 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0026	11754	4 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0027	11755	6 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0028	11756	4 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	
0029	11757	dimmer				1	Pass		20A	pass	P/F Pass	N/A		Pass	
0030	11758	2 way				1	Pass	13	20A	pass	P/F Pass	N/A	Polarity ok	Pass	

PORTABLE APPLIANCE TEST CERTIFICATE

GRAHAM WEBB ELECTRONICS Tel: 01525 375755

CONTINUATION SHEET

DATE OF TEST

26/06/2010

Please refer to top sheet for full details

ID No.	Label No.	Description	Location	Manufacturer	Serial No	Class 1-1 2-2 3-IT	Visual Pass /Fail	Fuse (Amps)	Earth 20A / 200ma	Bond	Insulation	Leak age	Comments	PASS	FAIL
0031	11759	6 way				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0032	11760	4 way				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0033	11761	4 way				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0034	11762	2 way				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0035	11763	ext lead				1	Pass	5	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0036	11764	4 way				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0037	11792	ext lead				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0038	11793	ext lead				1	Pass	13	20A	Pass	P/F Pass	N/A	Polarity ok	Pass	
0039	END	End							0		P/F	N/A			
0040									0		P/F	N/A			
0041									0		P/F	N/A			
0042									0		P/F	N/A			
0043									0		P/F	N/A			
0044									0		P/F	N/A			
0045									0		P/F	N/A			
0046									0		P/F	N/A			
0047									0		P/F	N/A			
0048									0		P/F	N/A			
0049									0		P/F	N/A			
0050									0		P/F	N/A			
0051									0		P/F	N/A			
0052									0		P/F	N/A			
0053									0		P/F	N/A			
0054									0		P/F	N/A			
0055									0		P/F	N/A			
0056									0		P/F	N/A			
0057									0		P/F	N/A			
0058									0		P/F	N/A			
0059									0		P/F	N/A			
0060									0		P/F	N/A			