

PORTABLE APPLIANCE TEST CERTIFICATE

GRAHAM WEBB ELECTRONICS Tel: 01525 375755

Customer		Designaband					
Site Address		email info@designaband.com					
H/O Address		129 Maryland road London N22 5AS					
Contact		David Brooks 020 8889 0553					
Manufacturer	Kewtech	Model	KT71	Serial	7000565	Date Calibrated	28/8/2009

DATE OF TEST	26/06/2010
NEXT TEST DATE	25/06/2011
ENGINEER	GW
AUTHORISATION No.	ZMN 251-1

ID No.	Label No.	Description	Location	Manufacturer	Serial No	Class 1-1 2-2 3-IT	Visual Pass /Fail	Fuse (Amps)	Earth 20A / 200ma	Bond	Insulation	Leak age	Comments	PASS	FAIL
0001	11765	Amplifier		Mesa		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0002	11766	pedal power		voodoo lab		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0003	11767	lead				1	Pass	13	20A	Pass	P/F Pass	N/A		Pass	
0004	11768	power sply				2	Pass		N/A		P/F Pass	N/A	visual only	Pass	
0005	11770	power sply				2	Pass		N/A		P/F Pass	N/A	visual only	Pass	
0006	11771	power sply		apple		3	Pass		200ma		N/A	P/F	visual only	Pass	
0007	11772	8 way		surrguard		3	Pass	13	200ma	Pass	N/A	P/F Pass		Pass	
0008	11773	power sply				2	Pass		N/A		P/F pass	N/A		Pass	
0009	11774	lead for above				2	Pass	5	N/A		P/F pass	N/A		pass	
0010	11775	lead				1	Pass	13	20A	Pass	P/F pass	N/A		Pass	
0011	11776	lead				1	Pass	13	20A	Pass	P/F pass	N/A		Pass	
0012	11777	power sply		roland		2	Pass		N/A		P/F pass	N/A		Pass	
0013	11778	lead				2	Pass	5	N/A		P/F pass	N/A		Pass	
0014	11779	power sply		behringer		2	Pass		N/A		P/F pass	N/A		Pass	
0015	11780	ext lead				1	Pass	13	20A	Pass	P/F pass	N/A		Pass	
0016	11781	lead				1	Pass	13	20A	Pass	P/F pass	N/A		Pass	
0017	11782	pedal power				1	Pass		20A	Pass	P/F pass	N/A		Pass	
0018	11783	power sply				2	Pass		N/A		P/F pass	N/A		Pass	
0019	11784	adapt				1	Pass		20A		P/F	N/A	visual only	Pass	
0020	11785	power sply		power bank		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0021	11786	power sply		power bank		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0022	11787	lead				1	Pass	13	20A	Pass	P/F Pass	N/A		Pass	
0023	11788	amplifier		aquilar		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0024	11789	Amplifier		boogie		3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0025	11790	lead				1	Pass	13	20A	Pass	P/F pass	N/A		Pass	
0026	11791	amplifier				3	Pass		200ma	Pass	N/A	P/F Pass		Pass	
0027	END	End							0		P/F	N/A			
0028									0		P/F	N/A			
0029									0		P/F	N/A			
0030									0		P/F	N/A			